

Tested By:	Oliver Maguire	Document ID:	
Calibration Date	26/11/24	T13310078 - 26/11/2024	

Site Name :	Folsana Pressed Sections Ltd		Test Type:	Cal Check - Trade
Machine Location:	SIDNEY STREET BOLTON	Test Location: Site Address	Serial No:	T13310078
	BL3 6BF		Accuracy Class: III	

Units:	kg	e =	20.000
Max:	50000.000	d =	20.000
Min:	400.000	Divisions:	2500

Make:	John Maguire & Son
Model:	PMSL - weighbridge
Type:	Weighbridge

Indicator Model	VT300
Make	Vishay
Test Certificate	DK0199-R76-05.02 rev.1

TestWeights:	West Yorks 06.09.24	Substitute:	YES
Amount Wts:	20000 kg	TW%:	40%

Size:	15m x 3m
Capacity:	50,000kg
Increments:	20kg

Type Approval	DK0199.62 rev.5
---------------	------------------------

Test Weights: (EN45501 3.7.1)	
Test Weight Cert	11223
Test Date	06/09/2024
Identification	A1-27
Description	25 tonne blocks + small wts

Serial No:	T13310078
Printer:	TM-U295
Peripheral 1	
Peripheral 2	
Cable length:	25
Visibility:	Window

Load Cell	5223 65K
Make	Vishay Measurements Gro
Test Cert	R60/1991-GB-95.07
Cell Cap:	65K
No of cells:	4

Serial Nos	1 21100930	4 21321645
	2 21317787	5
	3 21321657	6

Preliminary Observations:

MaxPreLoad:	YES
Max9eBlank:	YES
TareDevice:	NO
TestDisplay:	YES
ExtIndication:	YES
TicketTest:	YES
PeripheralMark:	Correct
TACconditions:	YES
MarkingsEtc:	Correct
EnvironCon:	Fine
LRVisibility:	Window

Notes:	
--------	--

Error Tolerances:

≤500e permissible error = 1 e	≤ 10000 ka	+/- 20 ka
≥501e to ≤2000e permissible error = 2 e	≥ 10020 to ≤40000 kg	+/- 40 kg
≥2001e to 3000e permissible error = 3 e	≥ 40020 to 50000 kg	+/- 60 kg

Linearity, Hysteresis and Tare Weighing (EN45501A4.4 and A4.6 Tables 1-7). To include Min, Max and Error change points and one other load.

	Applied:	Indicated	Error:	Error(e):
ZeroLoad:	2000.000	2000.000	0.000	0.00
MinLoad:	4000.000	4000.000	0.000	0.00
200e:	6000.000	6000.000	0.000	0.00
500e:	10000.000	10000.000	0.000	0.00
1000e:	16000.000	16000.000	0.000	0.00
HalfMax:	20000.000	19996.000	-4.000	-0.20
SubLoad (3.7.3):	19782.000	19778.000	-4.000	-0.20
SubLoad2:	29782.000	29776.000	-6.000	-0.30
SubLoad3:	39782.000	39774.000	-8.000	-0.40
FLT:	4392.000			
SubLoad4:	44174.000	44164.000	-10.000	-0.50
D2000e:	19782.000	19778.000	-4.000	-0.20
DHalfMax:	20000.000	20000.000	0.000	0.00
D1000e:	16000.000	16000.000	0.000	0.00
D500e:	10000.000	10000.000	0.000	0.00
DMin:	4000.000	4000.000	0.000	0.00

Eccentric Loading Test (EN45501 3.6.2.2)

2	6	3	Error:
1	5	4	
2	6	7	3
1	5	8	4
CornerLoad:	6392.000	CL1Ind:	-2.000
No. of LoadPoints:	4	CL2Ind:	-2.000
MPE+/-:	20 kg	CL3Ind:	2.000
		CL4Ind:	2.000
		CL5Ind:	
		CL6Ind:	
		CL7Ind:	
		CL8Ind:	

Repeatability and suitability for Substitution of Standard weights test (EN45501 3.6.1; 3.7.3) - 3 weighs for Class III

HalfMax1:		Max1:	
HalfMax2:		Max2:	
HalfMax3:		Max3:	
Range:	0.00	Range:	0.00
MPE +/-	40 kg	MPE +/-	40 kg

Authorised Signature	
Result:	PASS
Next Due:	30/11/2025